

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR- AF0004

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

MK2 Door Selector / Co-ordinator (Size 3 to 6)

Intended use:- For use on fire rated double leaf doors.

Essential characteristics	Performance	Harmonised technical specification
	Mechanical Test Evidence : 182032, WIL 361433 & WIL 399451 Iss 3. Fire Test Evidence : FCA/00134 rev A.	
Self closing	Pass	EN 1158:1997/A1:2002/AC:2006
5.1 Product Information and design		
5.2.1 General		
5.2.2 Overload performance		
5.2.3 Manipulation performance		
5.2.4 Resistance of Waiting		
5.2.6 Damage		
5.2.8 Fire/smoke door suitability	Pass	
Essential characteristics	Performance	Harmonised technical specification
Durability of Self Closing	(Grade 5)	EN 1158:1997/A1:2002/AC:2006
5.2.5 Durability	50,000 test cycles	
5.2.17.1 corrosion	Grade 3 (96 hours)	
5.2.17.2 corrosion	Pass	
Dangerous Substances Annex ZA3	Pass: the materials in the door coordinator do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	

Certificate of constancy of performance

2812-CPR-AF0004

Placed on the Market under the Name of

**Selectrite Hardware Ltd
Unit 12, Ladbroke Park, Millers Road, Warwick,
Warwickshire, CV34 5AN**

and produced in the manufacturing plant

E/182

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in Annex ZA of the standard(s):

EN 1158:1997/A1:2002

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 10/11/2020 and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

Valid to: **19/04/2023**

ERO Project Reference: **EROWF11109**



Paul Duggan
Certification Manager

