

Notified body No. 1121  
Warrington Certification Limited, Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK

## Certificate of constancy of performance

**1121-CPR-AF0004**

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

### SEL 2 Door Selector / Co-ordinator (Size 3 to 5)

**Intended use:- For use on fire rated double leaf doors.**

Essential characteristics	Performance	Harmonised technical specification
	Test Ref's : 182032, WIL 361433 & IFCA/00134 rev A.	
Self closing		EN 1158:1997/A1:2002/AC:2006
5.1 Product Information and design	Pass	
5.2.1 General	Pass	
5.2.2 Overload performance	Pass	
5.2.3 Manipulation performance	Pass	
5.2.4 Resistance of Waiting	Pass	
5.2.6 Damage	Pass	
5.2.8 Fire/smoke door suitability	Pass	
Essential characteristics	Performance	Harmonised technical specification
Durability of Self Closing	(Grade 5)	EN 1158:1997/A1:2002/AC:2006
5.2.5 Durability	50,000 test cycles	
5.2.17.1 corrosion	Grade 3 (96 hours)	
5.2.17.2 corrosion	Pass	
Dangerous Substances Annex ZA3	Pass: the materials in the door coordinator do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	

## Certificate of constancy of performance

**1121-CPR-AF0004**

Produced for

**Selectrite Hardware  
Unit 12, Ladbroke Park, Millers Road, Warwick,  
Warwickshire, CV34 5AN**

and produced in the manufacturing plant

**E/182**

**This is coded format and the information is held by the Notified Body.**


This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

**EN 1158:1997/A1:2002**

under system 1 of AVCP are applied and that

***the product fulfils all the prescribed requirements set out above.***

This certificate was first issued on **18/05/2016** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Paul Duggan  
Certification Manager  
Warrington Certification Ltd

