

**CONSTRUCTION PRODUCTS REGULATION (EU) 305/2011**  
**DECLARATION OF PERFORMANCE**

**DOP N°: FDC001**

1. Unique identification code of the product type:

**SEL2 / MK2**

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

**SEL MK2 – DOOR COORDINATOR IN VARIOUS FINISHES**

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

**FOR USE ON DOUBLE DOORS AND FIRE AND SMOKE COMPARTMENTATIONAL DOORS**

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11 (5):

**Selectrite Hardware,  
Unit 12 Ladboke Park Industrial Estate,  
Millers Road,  
Warwick,  
CV34 5AN**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

**N/A**

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

**System 1**

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

**EN 1158:1997+A1:2002**  
**UKAS accredited testing laboratory number 0621 and EC Notified body number 1104.**  
**Test Report Number: 182032**

8. European Technical Assessment:

**N/A**

9. Declared performance

Essential characteristics	Performance	Harmonised technical specification
<p><b>Self-closing</b></p> <p>5.1.2</p> <p>5.1.3</p> <p>5.2.1 General</p> <p>5.2.2 Closing overload performance</p> <p>5.2.3 Manipulation performance</p> <p>5.2.4 Resistance of waiting position</p> <p>5.2.6 Damage</p> <p>5.2.8 Fire/smoke door suitability</p>	<p>The device has been supplied with all parts necessary for its correct operation.</p> <p>The device enables the correct coordination of the door leaves from any opening angle with the use of a carry bar.</p> <p>The device withstands a moment of 300N without damage</p> <p>With the leaves closed in the wrong sequence, the operation of the active leaf to a maximum of 40° restores the correct coordination operation</p> <p>Pass</p> <p>Throughout the test program there is no damage to the door coordinator device which would adversely affect its performance</p> <p>Grade 1: suitable for use on fire/smoke door assemblies</p>	<p><b>EN 1158:1997+ A1:2002</b></p>
<p><b>Durability of self-closing</b></p> <p>5.2.5 Durability</p> <p>5.2.7.1 Corrosion resistance</p> <p>5.2.7.2 Corrosion resistance</p>	<p>Grade 5: 50 000 test cycles</p> <p>Grade 3: high resistance (96 hours)</p> <p>After being subjected to the spray test the device meets the requirement "Manipulation performance" of clause 5.2.3</p>	
<p><b>Dangerous substances</b></p> <p>Clause Za.3</p>	<p>The materials in this product do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations</p>	

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

The declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

.....Mark Townend - Managing Director.....  
(name and function of the person producing the DoP)

.....Warwick, UK - 24/05/2013.....  
(place and date of issue)

